

## Z-Wave Protocol Implementation Conformance Statement

### Strips Drip 700

#### General Information

<b>Product Identifier:</b>	11 04 023
<b>Brand Name:</b>	Sensitive
<b>Product Version:</b>	HW: 2 FW: 6.22
<b>Z-Wave Certification #:</b>	ZC12-21010158

#### Product Features

<b>Battery Quantity</b>	1
<b>Battery Type</b>	Built in 3.0V LiMnO2
<b>Color</b>	White
<b>Firmware Updatable</b>	Updatable by Consumer by RF
<b>Outdoor Use</b>	Yes

#### Z-Wave Product Information

Supports Z-Wave Beaming Technology?	No
Supports Z-Wave Network Security?	Yes
Supports Z-Wave AES-128 Security S0?	No
Supports Security S2?	Yes: S2 Authenticated, S2 Unauthenticated
SmartStart Compatible?	Yes

#### Z-Wave Technical Information

<b>Z-Wave Frequency:</b>	Australia / New Zealand
<b>Z-Wave Product ID:</b>	0x000B
<b>Z-Wave Product Type:</b>	0x0004
<b>Z-Wave Hardware Platform:</b>	ZGM130
<b>Z-Wave Development Kit Version:</b>	7.13.3
<b>Z-Wave Library Type:</b>	Enhanced 232 Slave
<b>Z-Wave Device Type / Role Type:</b>	Notification Sensor / Reporting Sleeping Slave

# Z-Wave Protocol Implementation Conformance Statement

(Continued)

## Strips Drip 700

### Association Group Information

**Group # / Max**    **Description**

**Nodes**

1 / 1                    Group 1, the Lifeline group, includes all signals that are sent automatically to keep a central controller notified of the status of Strips Drip 700. This includes the battery level, the moisture\leakage and temperature levels, and moisture\leakage, high and low temperature notifications.

**Supported Command Classes (19):**

Application Status	Association Group Information V3
Association V2	Battery
Configuration V4	Device Reset Locally
Firmware Update Meta-Data V5	Indicator V3
Manufacturer Specific V2	Multi-Channel Association V3
Notification V8	Powerlevel
Security S2	Sensor Multilevel V11
Supervision	Transport Service V2
Version V3	Wake Up V2
Z-Wave Plus Info V2	