

Z-Wave Protocol Implementation Conformance Statement

Smart Dry Contact Switch 7 (ZRX Version)

General Information

| | |
|--------------------------------|------------------|
| Product Identifier: | DRYZRX |
| Brand Name: | WiDom |
| Product Version: | HW: 01 FW: 07.00 |
| Z-Wave Certification #: | ZC14-22050106 |

Z-Wave Product Information

| | |
|--------------------------------------|---|
| Supports Z-Wave Beaming Technology? | Yes |
| Supports Z-Wave Network Security? | Yes |
| Supports Z-Wave AES-128 Security S0? | No |
| Supports Security S2? | Yes: S2 Authenticated, S2 Unauthenticated |
| SmartStart Compatible? | Yes |

Z-Wave Technical Information

| | |
|--|--|
| Z-Wave Frequency: | India, South Africa, UAE, CEPT (Europe), Bahrain, Cyprus, Moldova, Egypt, French Guiana, Georgia, Iraq, Jordan, Kazakstan, Kuwait, Lebanon, Libya, Maldives, Mauritius, Nigeria, Oman, Philippines, Qatar, Saudi Arabia, Turkmenistan, Uzbekistan, Yemen, Algeria, Armenia |
| Z-Wave Product ID: | 0x0004 |
| Z-Wave Product Type: | |
| Z-Wave Hardware Platform: | ZGM130S037HGN2 / ZGM130S037HGN1 |
| Z-Wave Development Kit Version: | 7.16.3 |
| Z-Wave Library Type: | Enhanced 232 Slave |
| Z-Wave Device Type / Role Type: | Binary Switch DT / Always On Slave |

Association Group Information

| Group # / Max | Description |
|---------------|-------------|
| Nodes | |
| 1 / 8 | |
| 2 / 8 | |
| 3 / 8 | |
| 4 / 8 | |
| 5 / 8 | |

Z-Wave Protocol Implementation Conformance Statement

(Continued)

Smart Dry Contact Switch 7 (ZRX Version)

Supported Command Classes (18):

| | |
|------------------------------|--|
| Application Status | Association Group Information (AGI) V3 |
| Association V2 | Basic V2 |
| Binary Switch V2 | Central Scene V3 |
| Configuration V4 | Device Reset Locally |
| Firmware Update Meta Data V5 | Indicator V3 |
| Manufacturer Specific V2 | Multi Channel Association V3 |
| Powerlevel | Security 2 |
| Supervision | Transport Service V2 |
| Version V3 | Z-Wave Plus Info V2 |